



सीएसआईआर - राष्ट्रीय वनस्पति अनुसंधान संस्थान, लखनऊ
CSIR - NATIONAL BOTANICAL RESEARCH INSTITUTE, LUCKNOW
Rana Pratap Marg, Lucknow – 226 001
Tele Fax No. : 0522-2207819/2206019



Date: 13.12.2016

No: 8-105-16-P

Corrigendum-2

Please refer CSIR-NBRI tender advertisement published in news papers on November 24, 2016. For tender no. **8/105/16-P** only, of item UPS 20 KVA, (Sr. No. 2), the following correction in specifications and due date may be noted by prospective bidders for further necessary action :-

Sr.No	Nature of corrigendum	For existing entries	Read as
1	Correction in specifications of 20 KVA UPS, 3 phase input and single phase output, (Battery) Sr. no. 4, VAH Required	~ 24800	~ 50000
2	Correction in specifications of 20 KVA UPS, 3 phase input and 3 phase output, (Battery) Sr. no. 4, VAH Required	~ 24800	~ 50000
3	Due Date of tender	16.12.2016	26.12.2016

All the other details, timings , terms and conditions etc. will remain same.

Stores & Purchase officer